



**Andy Beshear**  
GOVERNOR

**CABINET FOR HEALTH AND FAMILY SERVICES  
OFFICE OF INSPECTOR GENERAL**

**Eric Friedlander**  
SECRETARY

**Melissa A. Moore, Director**  
Division of Regulated Child Care  
Western Branch  
901 B South Main Street  
Hopkinsville, KY 42240  
Phone: (270) 889-6052 Fax: (270) 889-6089  
<https://chfs.ky.gov/agencies/os/oig>

**Adam Mather**  
INSPECTOR GENERAL

**Inspection Report**

<b>Provider Name:</b> iKids Childhood Enrichment Center	<b>Provider Information</b>	<b>CLR No:</b> L356601
<b>Provider Address:</b> 1471 U. S. Highway 68 West, Benton, KY, 42025	<b>Provider Type:</b> LICENSED TYPE I	<b>Capacity:</b> 97
<b>Owner(s):</b> iKids, Inc.		<b>Director(s):</b> Washburn, Jennifer Jean

<b>Inspection Type:</b> Renewal Application	<b>Inspection Information</b>	<b>Inspection No:</b> 292662
<b>Date Initiated:</b> 02/10/2020 10:00 AM	<b>Date Concluded:</b> 02/10/2020 1:55 PM	
	<b>No. of Children Present:</b> 48	

Inspection Report		
	<b>Background Checks</b>	<b>In Compliance</b>
	<b>Supervision</b>	<b>In Compliance</b>
	<b>Staffing Requirements</b>	<b>In Compliance</b>
	<b>General Administration</b>	<b>In Compliance</b>
	<b>Director Requirements</b>	<b>In Compliance</b>
	<b>Employee Records</b>	<b>In Compliance</b>
	<b>Programming</b>	<b>In Compliance</b>
	<b>Premises</b>	<b>Not In Compliance</b>
<b>645 - Sink</b>		<b>Not In Compliance</b>
<b>922 KAR 2:120. Section 10. Toilet, Diapering, and Toiletry Requirements.</b> <b>(3) A sink shall be:</b> <b>(a) Located in or immediately adjacent to toilet rooms;</b> <b>(b) Equipped with hot and cold running water that allows for hand washing;</b> <b>(c) Equipped with hot water at a minimum temperature of ninety (90) degrees Fahrenheit and a maximum of 120 degrees Fahrenheit;</b> <b>(d) Equipped with liquid soap;</b> <b>(e) Equipped with hand-drying blower or single use disposable hand drying material;</b> <b>(f) Equipped with an easily cleanable waste receptacle; and</b> <b>(g) Immediately adjacent to a changing area used for infants and toddlers.</b>		
<b>Findings:</b> General: Based on observation, the hot water registered eighty (80) degrees Fahrenheit at a sink located in the toddler room #1. The hot water registered seventy-nine (79) degrees Fahrenheit at a sink located in the toddler room #2. The hot water registered seventy-nine (79) degrees Fahrenheit at four (4) sinks in the school age restroom. The hot water registered seventy-two (72) degrees Fahrenheit at two (2) sinks in preschool room #1. The hot water registered sixty-five (65) degrees Fahrenheit at two (2) sinks in preschool room #2. The hot water registered eighty (80) degrees Fahrenheit at two (2) sinks in preschool room #3. The hot water registered sixty-five (65) degrees Fahrenheit at two (2) sinks in preschool room #4 and the the hot water registered sixty-eight (68) degrees Fahrenheit at two (2) sinks in preschool room #5.		
	<b>Hygienic Practices</b>	<b>In Compliance</b>
	<b>First Aid/Medication</b>	<b>In Compliance</b>
	<b>Outdoor Play Area</b>	<b>In Compliance</b>
	<b>Equipment</b>	<b>In Compliance</b>
	<b>Transportation</b>	<b>Not Applicable</b>

Inspection Report		
	<b>Food Service/Food Program</b>	<b>In Compliance</b>
	<b>Food Service</b>	<b>In Compliance</b>
	<b>Children's Records</b>	<b>In Compliance</b>
	<b>Written Documentation</b>	<b>In Compliance</b>
	<b>Posted Documentation</b>	<b>In Compliance</b>
	<b>Animals</b>	<b>In Compliance</b>

Signature of Provider/Representative

Title

Date