



**Andy Beshear**  
GOVERNOR

**CABINET FOR HEALTH AND FAMILY SERVICES**  
**OFFICE OF INSPECTOR GENERAL**

**Eric Friedlander**  
SECRETARY

**Melissa A. Moore, Director**  
Division of Regulated Child Care  
Eastern Branch  
455 Park Place, Suite 120A  
Lexington, KY 40511

**Adam Mather**  
INSPECTOR GENERAL

Phone: (859) 246-2301 Fax: (859) 246-2307  
<https://chfs.ky.gov/agencies/os/oig>

**Inspection Report**

<b>Provider Name:</b> Just Like Home II Childcare Center	<b>Provider Information</b> <b>Provider Type:</b> LICENSED TYPE I	<b>CLR No:</b> L358925
<b>Provider Address:</b> 104 Canewood Drive, Suites 4 And 5, Georgetown, KY, 40324		<b>Capacity:</b> 57
<b>Owner(s):</b> Bailey, Nichole & Gividen, Alycia Alejandro		<b>Director(s):</b> Hale, Crystal

<b>Inspection Type:</b> Renewal Application	<b>Inspection Information</b>	<b>Inspection No:</b> 323423
<b>Date Initiated:</b> 11/07/2022 9:11 AM	<b>Date Concluded:</b> 11/07/2022 11:25 AM	
	<b>No. of Children Present:</b> 27	

Inspection Report	
Background Checks	In Compliance
Supervision	In Compliance
Staffing Requirements	In Compliance
General Administration	In Compliance
Director Requirements	In Compliance
Employee Records	In Compliance
Programming	In Compliance
Premises	Not In Compliance
<b>625 - Floors, Walls, Ceilings</b>	<b>Not In Compliance</b>
<b>922 KAR 2:120. Section 4. Premises Requirements.</b>	
<b>(9) Floors, walls, and ceilings shall be smooth, in good repair, and constructed to be easily cleaned.</b>	
<b>Findings:</b>	
General: Based on observation, the child care center failed to maintain state regulations. The One's Room contained two holes in the wall on the right side, exposing the drywall screws underneath.	
<b>690 - Sink</b>	<b>Not In Compliance</b>
<b>922 KAR 2:120. Section 12. Toilet, Diapering, and Toiletry Requirements.</b>	
<b>(3) A sink shall be:</b>	
<b>(a) Located in or immediately adjacent to toilet rooms;</b>	
<b>(b) Equipped with hot and cold running water that allows for hand washing;</b>	
<b>(c) Equipped with hot water at a minimum temperature of ninety (90) degrees Fahrenheit and a maximum of 120 degrees Fahrenheit;</b>	
<b>(d) Equipped with liquid soap;</b>	
<b>(e) Equipped with hand-drying blower or single use disposable hand drying material;</b>	
<b>(f) Equipped with an easily cleanable waste receptacle; and</b>	
<b>(g) Immediately adjacent to a changing area used for infants and toddlers.</b>	
<b>Findings:</b>	
General: Based on observation, the child care center failed to maintain state regulations. During the survey, it was found that the water temperature throughout the center did not reach the minimum temperature of ninety (90) degrees Fahrenheit.	
<b>Hygienic Practices</b>	<b>In Compliance</b>

**Inspection Report**

<b>First Aid/Medication</b>	<b>In Compliance</b>
<b>Outdoor Play Area</b>	<b>In Compliance</b>
<b>Equipment</b>	<b>In Compliance</b>
<b>Transportation</b>	<b>Not Applicable</b>
<b>Kitchen Requirements</b>	<b>In Compliance</b>
<b>Food Service</b>	<b>In Compliance</b>
<b>Meal Planning/Center Provides Meals</b>	<b>In Compliance</b>
<b>Meal Planning/Center Does Not Provide Meals</b>	<b>In Compliance</b>
<b>Children's Records</b>	<b>In Compliance</b>
<b>Written Documentation</b>	<b>In Compliance</b>
<b>Posted Documentation</b>	<b>In Compliance</b>
<b>Animals</b>	<b>Not Applicable</b>

---

Signature of Provider/Representative

Title

Date