



Andy Beshear
GOVERNOR

**CABINET FOR HEALTH AND FAMILY SERVICES
OFFICE OF INSPECTOR GENERAL**

Eric Friedlander
SECRETARY

Melissa A. Moore, Director
Division of Regulated Child Care
Western Branch
901 B South Main Street
Hopkinsville, KY 42240

Adam Mather
INSPECTOR GENERAL

Phone: (270) 889-6052 Fax: (270) 889-6089
<https://chfs.ky.gov/agencies/os/oig>

Inspection Report

Provider Name: Hopkinsville Child Development Center	Provider Information	CLR No: L358935
Provider Address: 2511 Fort Campbell Blvd., Hopkinsville, KY, 42240	Provider Type: LICENSED TYPE I	Capacity: 30
Owner(s): Aviles, Daisy		Director(s): Aviles, Daisy

Inspection Type: Change of Location	Inspection Information	Inspection No: 216604
Date Initiated: 09/07/2016 8:00 AM	Date Concluded: 09/07/2016 9:25 AM	
	No. of Children Present:	

Inspection Report	
General Administration	In Compliance
Programming	In Compliance
Premises	Not In Compliance
585 - Sink	Not In Compliance
<p>922 KAR 2:120. Section 10. Toilet, Diapering, and Toiletry Requirements.</p> <p>(3) A sink shall be:</p> <ul style="list-style-type: none"> (a) Located in or immediately adjacent to toilet rooms; (b) Equipped with hot and cold running water that allows for hand washing; (c) Equipped with hot water at a minimum temperature of ninety (90) degrees Fahrenheit and a maximum of 120 degrees Fahrenheit; (d) Equipped with liquid soap; (e) Equipped with hand-drying blower or single use disposable hand drying material; (f) Equipped with an easily cleanable waste receptacle; and (g) Immediately adjacent to a changing area used for infants and toddlers. <p>Findings:</p> <p>General: Based on Observation, the hot water temperature registered one hundred twenty-six (126) degrees Fahrenheit at two (2) sinks in the girls' restroom and at two (2) sinks in the boys' restroom.</p>	
Equipment	In Compliance
Food Service	In Compliance

Signature of Provider/Representative

Title

Date