



**CABINET FOR HEALTH AND FAMILY SERVICES
OFFICE OF INSPECTOR GENERAL**

Andy Beshear
Governor

Melissa A. Moore, Director
Division of Regulated Child Care
Northern Branch
908 W. Broadway, 10-W
Louisville, KY 40203
Phone: (502) 595-5781 Fax: (502) 595-5773
<https://chfs.ky.gov/agencies/os/oig>

Eric C. Friedlander
Secretary

Adam Mather
Inspector General

Inspection Report

Provider Name: Kribs2Kids	Provider Information	CLR No: L358984
Provider Address: 111 Fairmeade Road, Louisville, KY, 40207	Provider Type: LICENSED TYPE I	Capacity: 55
Owner(s): Kribs2Kids, LLC		Director(s): Benny, Ravisha

Inspection Type: Investigation	Inspection Information	Inspection No: 292375
Date Initiated: 12/16/2019 1:00 PM	Date Concluded: 12/16/2019 2:30 PM	
	No. of Children Present: 25	

Inspection Report	
Supervision	In Compliance
Staffing Requirements	In Compliance
Premises	Not In Compliance
580 - Floors, Walls, Ceilings	Not In Compliance
922 KAR 2:120. Section 4. Premises Requirements.	
(9) Floors, walls, and ceilings shall be smooth, in good repair, and constructed to be easily cleaned.	
Findings:	
General: Based on observation and interview, the child care center failed to maintain the premises in accordance with regulatory requirements. Upon observation and interview of the facility it was observed that ceiling tiles were missing in the two year old room and the toddler room. It was observed that the floor was damaged from water causing the flooring to be pulled back, exposing water damage to the concrete below in both the infant room and the pre-K room up at the front where the glass windows go down to the floor. Interview with the staff in charge revealed that the roof had recently been repaired and there was still water damage to the ceilings and floors that needed repair.	

Signature of
Provider/Representative

Title

Date