

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Great After School Place - Medary**

City: **Brookings**

Provider Number: **011508868**

Inspector: **Charles Schmidt**

Date of Inspection: **10/30/2018**

Time of Inspection: **2:51 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

9. In rooms used for the program is the electrical system being used properly; no overloads or frayed extension cords? 61:15:07:24

<p>Corrections To Be Made:</p> <p><b>Non - surge protected cord to power strip. Recommend proper length surge protected power strip.</b></p> <p><b>**Proper length surge protected power strip purchased.**</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>11/30/2018</b></td> <td style="text-align: center;"><b>11/16/2018</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>11/30/2018</b>	<b>11/16/2018</b>
Suggested Completion Date:	Actual Completion Date:				
<b>11/30/2018</b>	<b>11/16/2018</b>				

**Clint Rinehart**

**10/30/2018**

Provider Signature

Date

**Charles Schmidt**

**10/30/2018**

Inspector Signature

Date