

Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Great After School Place - Medary Elementary**

City: **Brookings**

Provider Number: **011508868**

Inspector: **Charles Schmidt**

Date of Inspection: **10/15/2020**

Time of Inspection: **7:24 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

4. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>South West Exit sign "flickering". Ensure sign is operating correctly. Battery replaced in Exit sign and is now in working condition.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/22/2020</td> <td style="text-align: center;">10/23/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/22/2020	10/23/2020
Suggested Completion Date:	Actual Completion Date:				
10/22/2020	10/23/2020				

Nicole

10/15/2020

Provider Signature

Date

Charles Schmidt

10/15/2020

Inspector Signature

Date