

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Kid's World Learning Center**      City: **Brookings**      Provider Number: **011512327**  
 Inspector: **Charles Schmidt**      Date of Inspection: **01/25/2019**      Time of Inspection: **1:50 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

15. Is electrical system being used properly? 61:15:01      NOTE: Check for overloads or frayed extension cords.

<p>Corrections To Be Made:</p> <p><b>Make sure to plug refrigeration units directly into wall outlets.</b></p> <p><b>**Refrigerator plugged directly into wall outlet.**</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>01/31/2019</b></td> <td style="text-align: center;"><b>01/25/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>01/31/2019</b>	<b>01/25/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>01/31/2019</b>	<b>01/25/2019</b>				

## C. FOOD SERVICE

95. Are all utensils/equipment stored at least six inches above the floor in a clean, dry, protected location, and not placed under exposed sewer or water lines except for fire protection sprinkler lines?  
67:42:11:29

Corrections To Be Made:

**Store pesticide bottles & cleaning chemicals away from childrens items stored in utility room cabinet.**

**\*\*Cleaning supplies were removed from closet and placed away from any and all child items.\*\***

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**01/25/2019**

**01/25/2019**

Status: **Corrected Immediately**

**Pam Grygiel**

Provider Signature

**01/25/2019**

Date

**Charles Schmidt**

Inspector Signature

**01/25/2019**

Date