

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Kid's World Learning Center** City: **Brookings** Provider Number: **011512327**
 Inspector: **Eric Anderson** Date of Inspection: **07/08/2020** Time of Inspection: **1:38 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

15. Is electrical system being used properly? 61:15:01 NOTE: Check for overloads or frayed extension cords.

<p>Corrections To Be Made:</p> <p>Replace power strip in majors room. Outlet plugs needed in the excel room. Relieve pressure on the power strips behind the desk by pulling desk out some. corrected immediately</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">07/31/2020</td> <td style="text-align: center;">07/08/2020</td> </tr> </table> <p>Status: Corrected Immediately</p>	Suggested Completion Date:	Actual Completion Date:	07/31/2020	07/08/2020
Suggested Completion Date:	Actual Completion Date:				
07/31/2020	07/08/2020				

Liz Scheidt

 Provider Signature

07/08/2020

 Date

Eric Anderson

 Inspector Signature

07/08/2020

 Date