

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **SDSU Preschool**

City: **Brookings**

Provider Number: **011515520**

Inspector: **Charles Schmidt**

Date of Inspection: **01/31/2019**

Time of Inspection: **3:43 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

13. In areas providing access to exits, do combustible decorations cover less than 10% of the wall area?
61:15:05:05

<p>Corrections To Be Made:</p> <p>Main corridor has multiple bulletin boards greater than 50% wall coverage.</p> <p>**Wall space cleared.**</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">02/28/2019</td> <td style="text-align: center;">02/28/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	02/28/2019	02/28/2019
Suggested Completion Date:	Actual Completion Date:				
02/28/2019	02/28/2019				

Laura Gloege

Provider Signature

01/31/2019

Date

Charles Schmidt

Inspector Signature

01/31/2019

Date