Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: SDSU Preschool City: Brookings Provider Number: 011515520

Inspector: Charles Schmidt Date of Inspection: 10/22/2020 Time of Inspection: 7:59 AM

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made: Agency Action:

Ensure emergency lighting is in operable condition. Compliance Plan

Ensure emergency lighting is in operable condition.

Emergency lighting has been fixed and in operable condition.

Suggested Completion Completion
Date: Date:

10/31/2020 11/05/2020

Status: Corrected

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

Corrections To Be Made: Agency Action:

Items need to be stored less than 24" from ceiling. Items should be

removed from ceilings/l-beams/conduit.

All items have been removed from ceiling area or items are less than 2 feet

below the ceiling.

Compliance Plan

Suggested Actual Completion Completion Date: Date:

Date: Date:

10/31/2020 10/29/2020

Status: Corrected

Laura Gloege	10/22/2020	Charles Schmidt	10/22/2020
Provider Signature	Date	Inspector Signature	Date