

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **St. Thomas More Preschool**      City: **Brookings**      Provider Number: **011515539**  
 Inspector: **Charles Schmidt**      Date of Inspection: **03/27/2018**      Time of Inspection: **2:27 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

**Ensure all flood lights and exit signs are functioning correctly.**

Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

**03/30/2018**

Actual  
Completion  
Date:

**04/17/2018**

Status: **Corrected**

**Jerry Nissen**

Provider Signature

**03/27/2018**

Date

**Charles Schmidt**

Inspector Signature

**03/27/2018**

Date