

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **St Thomas More Preschool**

City: **Brookings**

Provider Number: **011515539**

Inspector: **Charles Schmidt**

Date of Inspection: **01/31/2019**

Time of Inspection: **9:13 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

15. Is electrical system being used properly? 61:15:01 NOTE: Check for overloads or frayed extension cords.

Corrections To Be Made:

**Replacement of cord with surge protected power strip needed.**

**\*\*Cord replaced with proper surge protected power strip.\*\***

Agency Action:

### Compliance Plan

Suggested  
Completion  
Date:

**02/28/2019**

Actual  
Completion  
Date:

**01/31/2019**

Status: **Corrected**

**Meghan Kelly**

Provider Signature

**01/31/2019**

Date

**Charles Schmidt**

Inspector Signature

**01/31/2019**

Date