

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **St. Thomas More Preschool**

City: **Brookings**

Provider Number: **011515539**

Inspector: **Charles Schmidt**

Date of Inspection: **10/22/2020**

Time of Inspection: **12:31 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are exits and exit corridors maintained in a safe manner? 61:15:05:05 NOTE: Exits can't pass through storeroom, bathroom, kitchen; corridor & aisle widths of 36 inches; exits cannot be obstructed.

Corrections To Be Made:

Remove coiled water hose from exit. Represents trip hazard.

.....

Hose has been moved from exit area.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/31/2020

Actual
Completion
Date:

11/02/2020

Status: **Corrected**

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

Corrections To Be Made:

Store combustible items >24" from ceilings.

.....

Items have been removed and/or stored more than 24 inches from ceiling.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/31/2020

Actual
Completion
Date:

11/02/2020

Status: **Corrected**

Meghan

Provider Signature

10/23/2020

Date

Charles Schmidt

Inspector Signature

10/23/2020

Date