

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Prairie Hills Child Care Center** City: **Spearfish**

Provider Number: **016598172**

Inspector: **Terra Robbins** Date of Inspection: **06/24/2020**

Time of Inspection: **12:03 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

17. If commercial cooking equipment is installed, is an automatic hood suppression system installed for the protection of deep fat fryers, griddles, upright broilers, char-broilers, range tops, and grills with setup? Has the system been inspected every 6 months? 61:15:01

<p>Corrections To Be Made:</p> <p>The commercial cooking equipment must be inspected every 6 months. The last inspection was in 2018.</p> <p>*The program had the cooking equipment inspected and verification was sent to CCS.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">07/24/2020</td> <td style="text-align: center;">07/16/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	07/24/2020	07/16/2020
Suggested Completion Date:	Actual Completion Date:				
07/24/2020	07/16/2020				

Karley LaFountain

Provider Signature

06/24/2020

Date

Terra Robbins

Inspector Signature

06/24/2020

Date