

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Dream Kids Preschool and Children's Center**

City: **Rapid City**

Provider Number: **016598651**

Inspector: **Jon Farrar**

Date of Inspection: **06/25/2019**

Time of Inspection: **8:06 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p><b>Potential combustibles are reaching the ceiling in storage closet. Combustible materials must be maintained at least 2 feet below the ceiling or 18 inches below sprinkler heads.</b></p> <p><b>*Combustible materials were moved. The program sent CCS a picture of the storage area showing that the materials were at least 18 inches below sprinkler heads.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>07/01/2019</b></td> <td style="text-align: center;"><b>07/10/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>07/01/2019</b>	<b>07/10/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>07/01/2019</b>	<b>07/10/2019</b>				

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

<p>Corrections To Be Made:</p> <p><b>Hallway needs fire extinguisher with no more than 75 feet travel distance.</b></p> <p><b>*A new fire extinguisher was purchased and placed in the hallway. A picture was sent to CCS to verify compliance.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>07/07/2019</b></td> <td style="text-align: center;"><b>07/10/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>07/07/2019</b>	<b>07/10/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>07/07/2019</b>	<b>07/10/2019</b>				

**LeeAnn Maude**

Provider Signature

**06/25/2019**

Date

**Jon Farrar**

Inspector Signature

**06/25/2019**

Date