

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Good News Children's Center** City: **Sioux Falls** Provider Number: **018038530**
 Inspector: **Stacy Wildermuth** Date of Inspection: **01/08/2019** Time of Inspection: **10:12 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>The heating and cooling system has not had an annual inspection. This should be completed annually.</p> <p>***The documentation for the current heating and cooling inspection system was received by Child Care Services.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">02/08/2019</td> <td style="text-align: center;">01/31/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	02/08/2019	01/31/2019
Suggested Completion Date:	Actual Completion Date:				
02/08/2019	01/31/2019				

Tammy
Provider Signature

01/08/2019
Date

Stacy Wildermuth
Inspector Signature

01/08/2019
Date