

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Christ The King School**

City: **Sioux Falls**

Provider Number: **018042186**

Inspector: **Dwight Johnson**

Date of Inspection: **02/11/2020**

Time of Inspection: **4:15 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

<p>Corrections To Be Made:</p> <p>The measured water temperature at the sink in the boy's bathroom is 125.8 degrees F.</p> <p>*Water temperature tested at 118 degrees.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table border="0"> <tr> <td style="text-align: center;">Suggested Completion Date:</td> <td style="text-align: center;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/11/2020</td> <td style="text-align: center;">02/20/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/11/2020	02/20/2020
Suggested Completion Date:	Actual Completion Date:				
03/11/2020	02/20/2020				

58. Are cleaning supplies kept inaccessible to children? 67:42:11:40

<p>Corrections To Be Made:</p> <p>Cleaning supplies accessible to children in a storage room with programs toys, equipment and gear.</p> <p>*Cleaning supplies inaccessible to children.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table border="0"> <tr> <td style="text-align: center;">Suggested Completion Date:</td> <td style="text-align: center;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/11/2020</td> <td style="text-align: center;">02/20/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/11/2020	02/20/2020
Suggested Completion Date:	Actual Completion Date:				
03/11/2020	02/20/2020				

Marijana Cosic

Provider Signature

02/11/2020

Date

Dwight Johnson

Inspector Signature

02/11/2020

Date