

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Sioux Falls Christian School** City: **Sioux Falls** Provider Number: **018042354**
 Inspector: **Charles Anderson** Date of Inspection: **06/20/2018** Time of Inspection: **11:36 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

7. In Licensed Day Care Programs Caring for 21 or More Children - Is a fire alarm system installed in the building wiring and operable? 61:15:05:08 NOTE: Manual pull stations, audible alarms inside and out. Smoke detectors are in stairwells, corridors, lounges, recreation and sleeping areas.

<p>Corrections To Be Made:</p> <p>Please send a copy of the last inspection record to CCS. There is typically a tag inside or on top of the panel.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">07/04/2018</td> <td style="text-align: center;">07/30/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	07/04/2018	07/30/2018
Suggested Completion Date:	Actual Completion Date:				
07/04/2018	07/30/2018				

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

Please send the last 2 HVAC inspection reports to CCS.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

Actual
Completion
Date:

07/04/2018

07/10/2018

Status: **Corrected**

Bre Johnson

Provider Signature

06/20/2018

Date

Charles Anderson

Inspector Signature

06/20/2018

Date