

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **SnickleFritz Prep South**

City: **Harrisburg**

Provider Number: **018042503**

Inspector: **Dwight Johnson**

Date of Inspection: **06/25/2019**

Time of Inspection: **1:15 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?  
67:42:11:09

<p>Corrections To Be Made:</p> <p><b>The boy's bathroom hand-wash sink was measured at 128.8 degrees F. Water temperature to be no more than 120 degrees. *Water temperature measured 120 degrees on 07/29/19.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>07/01/2019</b></td> <td style="text-align: center;"><b>07/29/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>07/01/2019</b>	<b>07/29/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>07/01/2019</b>	<b>07/29/2019</b>				

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p><b>Documentation of HVAC inspection to be provided. *Documentation received.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>07/25/2019</b></td> <td style="text-align: center;"><b>08/21/2019</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>07/25/2019</b>	<b>08/21/2019</b>
Suggested Completion Date:	Actual Completion Date:				
<b>07/25/2019</b>	<b>08/21/2019</b>				

**Melissa Kuck**

Provider Signature

**06/25/2019**

Date

**Dwight Johnson**

Inspector Signature

**06/25/2019**

Date