

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Pitter Patter Playhouse**

City: **Sioux Falls**

Provider Number: **018042828**

Inspector: **Charles Anderson**

Date of Inspection: **03/07/2018**

Time of Inspection: **4:24 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. FOOD SERVICE

83. Are potentially hazardous foods properly thawed, i.e. in refrigerated unit with temp not exceeding 41 degrees F, under potable running water with temp 70 degrees F or below, in uninterrupted cooking process in microwave oven, or as part of conventional cooking process? 67:42:11:16

<p>Corrections To Be Made:</p> <p>Internal temperature of food items inside the kitchen refrigerator was 48F. Dairy products moved to other refrigerators. Lower setting, check in the morning. If temp is 41 or below food can be returned. Items more than 3 days old should be discarded.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table border="0"> <tr> <td style="padding-right: 20px;">Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td style="padding-right: 20px;">04/07/2018</td> <td>03/09/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	04/07/2018	03/09/2018
Suggested Completion Date:	Actual Completion Date:				
04/07/2018	03/09/2018				

98. If a 3-compartment sink is used for manual cleaning, are the compartments used for washing, rinsing and sanitizing? 67:42:11:07 NOTE: Sanitize by immersing for 30 seconds in 170 degree F water or immerse for 60 seconds in 75 degree F water containing 1 ounce household bleach per 4 gallons of water.

Corrections To Be Made:

Bottles and cups do not go through the 3 step cleaning process in the ones room. Staff put into place plastic "shoe box" size containers to complete the process.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

Actual
Completion
Date:

03/08/2018

03/07/2018

Status: **Corrected**

Michele Glatt

Provider Signature

03/07/2018

Date

Charles Anderson

Inspector Signature

03/07/2018

Date