## Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: Pitter Patter Playhouse City: Sioux Falls Provider Number: 018042828

Inspector: Kelly Gnat Date of Inspection: 04/30/2020 Time of Inspection: 9:50 AM

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

1. Are written emergency evacuation plans posted? 67:42:10:18

Corrections To Be Made: Agency Action:

Emergency evacuation plans to be posted. \*Plans observed on 05/20/20

Compliance Plan

Suggested Actual Completion Completion Date: Date:

05/30/2020 05/20/2020

Status: Corrected Immediately

7. In Licensed Day Care Programs Caring for 21 or More Children - Is a fire alarm system installed in the building wiring and operable? 61:15:05:08 NOTE: Manual pull stations, audible alarms inside and out. Smoke detectors are in stairwells, corridors, lounges, recreation and sleeping areas.

Corrections To Be Made:

Agency Action:

Compliance Plan

Fire alarm system to be in place and operational. \*Inspection documentation received on 07/06/20. Inspection was completed on 05/20/2020.

Suggested Completion Date: Actual Completion Date:

05/30/2020 07/07/2020

Status: Corrected

9. If a fire sprinkler system is present in the building, is it operational? 61:15:05:09 NOTE: Valves are open, observe pressure gauge reading and sprinkler head condition.

Corrections To Be Made: Agency Action:

Fire sprinkler system to be installed and operational. \*Documentation received on 07/06/20. Inspection completed on 05/18/20.

Compliance Plan

Suggested Completion Date:

Actual Completion Date:

05/30/2020

07/06/2020

Status: Corrected

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made: Agency Action:

Exit signs to be installed and operational. \*Signs observed on 05/20/2020.

Compliance Plan

Suggested Completion Date:

Actual Completion Date:

05/30/2020

05/20/2020

Status: Corrected

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made: Agency Action:

Fire extinguisher to be installed.
\*Extinguisher observed on 05/20/2020

Compliance Plan

Suggested Completion Date:

Actual Completion Date:

05/30/2020

05/20/2020

Status: Corrected

## **B. ENVIRONMENTAL HEALTH**

22. Does the construction of walls, ceilings, doors, window and skylights appear clean and in good repair?

Does outside appearance and construction appear in good repair? 67:42:11:39

Construction of ceilings to be completed
\*Construction of ceilings completed as of 05/20/2020

Suggested Completion Completion Date:

05/30/2020

Status: Corrected

65. Is there a fenced outdoor play area? Does the fenced area appear to allow for 50 square feet per child during each scheduled recess time? 67:42:11:02

Corrections To Be Made:

Fence to be installed
\*Fence installed as of 05/20/2020

Suggested
Completion
Date:

05/30/2020

Status: Corrected

Michele Glatt04/30/2020Kelly Gnat04/30/2020Provider SignatureDateInspector SignatureDate