

Bright from the Start Georgia Department of Early Care and Learning 2 Martin Luther King Jr. Drive SE, 670 East Tower Atlanta, GA 30334

Phone: (404) 657-5562 WWW.DECAL.GA.GOV

Date: 1/22/2019 VisitType: Complaint Closure from Arrival: 1:50 PM Departure: 5:00 PM

visit on 01/22/2019

CCLC-3064

Ark Angels Christian Learning Center

565 Hoyt Street Cornelia, GA 30531 Habersham County (706) 778-2270 arkangelsclcinc@gmail.com

Mailing Address

Same

Quality Rated: No

Regional Consultant

Colleen Covey

Phone: (706) 256-7245 Fax: (706) 256-7244

colleen.covey@decal.ga.gov

| | | | Compliance Zone Designation - A summary measure of a program's 12 month monitoring history, as it pertains to child care health and safety rules. The three compliance zones are good | | | | |
|------------|-----------------------------------|---------------|--|--|--|--|--|
| 01/22/2019 | Complaint Investigation Follow | Good Standing | standing, support, and deficient. | | | | |
| | Up | | | - Program is demonstrating an acceptable level of performance in meeting | | | |
| 01/22/2019 | | Good Standing | | the rules. - Program performance is demonstrating a need for improvement in meeting | | | |
| 08/28/2018 | Monitoring Visit | Good Standing | Deficient | rules Program is not demonstrating an acceptable level of performance in meeting | | | |
| | | | | the rules. | | | |

Comments

Advisement of Potential for Repeated Rule Violations during Pending Investigations

This report shall serve as official notice of potential rule violations. These potential rule violations have been detailed in this report and discussed with you by the consultant. The department shall conduct a thorough investigation to determine if in fact the alleged rule violation(s) should or should not be substantiated. Please be aware that the investigation may take some time to be finalized to ensure fairness and accuracy. During this investigation period, any violations of an identical rule or rules will require the department to treat any and all substantiated rule violations identified in the investigation as repeated rule violation(s).

Further, from time to time the department discovers additional rule violations during the course of an investigation. If there are new rule violation(s), your consultant shall inform you of the violation(s) as soon as possible. However, as stated above, any violations of identical rule(s) will require the department to treat any and all additional rule violations identified in the investigation as repeated rule violations.

All rule violations found in relation to a complaint or incident investigation will be associated with the date the investigation was closed.



Reminder: <u>All</u> employees of child care programs must be fingerprinted before **January 1, 2017**. For instructions and to submit records check applications online, please visit www.decalkoala.com. You are encouraged not to wait and to complete the process as soon as possible.

O.C.G.A. Section 42.1.12(i)(2) requires Bright from the Start: Georgia Department of Early Care and Learning to notify licensed child care programs on accessing and retrieving from the Georgia Bureau of Investigation's (GBI) website a list of the names and addresses of all registered sexual offenders. Please see GBI's website located at http://gbi.georgia.gov to access the Georgia Sex Offender Registry.

| Refutation Process: | | | | | | | | |
|--|---|---|---|---|--|--|--|--|
| You have the right to refute any of the citations r to CCSRefutations@decal.ga.gov. | oted in this repo | ort with which you disagree. | To refute a citation(s), e- | -mail the following information | | | | |
| 1) Facility name, license number and visit date 2) Your name, title/relationship to the facility, e-n 3) Specific rule number(s) that you are refuting, | | | | | | | | |
| Refutations must be submitted to Child Care Ser | vices (CCS) wit | hin 10 business days of the | completion date. | | | | | |
| A sample form for submitting a refutation can be found at: http://decal.ga.gov/ChildCareServices/RefutationInformation.aspx | | | | | | | | |
| Your refutation will be forwarded to the appropria this process, contact our office at 404-657-5562. | | er, who will follow up with yo | ou about your concerns. If | you have any questions about | | | | |
| Bright from the Start recommends that all licensed have this liability insurance, you are required to pupulardian of each child in care in writing, obtain the program at all times while the child attends the program at all times while the | ost a notice with eir signature to a | ½ inch letters in a conspicuacknowledge receipt and ma | ous location in the progra aintain this written acknow | m, notify the parent or reledgment on file at the | | | | |
| have read and understand the Rules and Regula been discussed with me and I have agreed to a P deficiencies, while required, will not necessarily p any of the deficiencies cited, I have the right to re | lan of Improven revent DECAL f | nent (POI) as indicated in thi rom taking adverse action a | s report. I understand that gainst this facility. I underst | at correction of these stand that if I disagree with | | | | |
| Rochelle Simmemon, Program Official | Date | Colleen Covey , Consult | ant | Date | | | | |



Bright from the Start Georgia Department of Early Care and Learning 2 Martin Luther King Jr. Drive SE, 670 East Tower Atlanta, GA 30334

Phone: (404) 657-5562 WWW.DECAL.GA.GOV

Summary Report

Arrival: 1:50 PM

Date: 1/22/2019 **VisitType:** Complaint Closure from

visit on 01/22/2019

Regional Consultant

Colleen Covey

Phone: (706) 256-7245 Fax: (706) 256-7244

colleen.covey@decal.ga.gov

Departure: 5:00 PM

CCLC-3064

Ark Angels Christian Learning Center

565 Hoyt Street Cornelia, GA 30531 Habersham County (706) 778-2270 arkangelsclcinc@gmail.com

Mailing Address

Same

The following information is associated with a Complaint Closure:

Facilit

591-1-1-.25 Physical Plant-Structural/Mechanical

Not Met

Finding Associated with Complaint

591-1-1-.25(4) requires the Center to maintain the temperature in the range of 65 to 85 degrees Fahrenheit and to ventilate the Center be ventilated either by mechanical or natural means for the purpose of providing fresh air and controlling unpleasant odors. Facilities which do not have a functioning central heating and air-conditioning system shall make fifty percent (50%) of all required windows operable for ventilation. Any openings used for ventilation shall be screened. It was determined during the coarse of the investigation that on Thursday, January 17, 2019 the center ran out of propane from approximately 9:30 AM until 1:00 PM. During that time space heaters were used in all the classroom except for the back room. The back room has a wall mounted electric heater. The space heaters were unable to maintain the required temperature of 65 degrees in the other four rooms. Staff stated that the rooms were cold, and children had to wear additional clothing and jackets. Staff stated that the temperature fell below 65 degrees.

POI (Plan of Improvement)

The Center will add screen(s), if needed. The designated person(s) will check frequently to ensure the Center's temperature is maintained at 65 to 85 degrees Fahrenheit, will monitor to ensure that either natural or mechanical ventilation provides fresh air and controls unpleasant odors, and that any openings used for ventilation are screened.

Correction Deadline: 1/22/2019