



**CABINET FOR HEALTH AND FAMILY SERVICES
OFFICE OF INSPECTOR GENERAL**

Andy Beshear
Governor

Melissa A. Moore, Director
Division of Regulated Child Care
Northern Branch
908 W. Broadway, 10-W
Louisville, KY 40203
Phone: (502) 595-5781 Fax: (502) 595-5773
<https://chfs.ky.gov/agencies/os/oig>

Eric C. Friedlander
Secretary

Adam Mather
Inspector General

Inspection Report

Provider Name: Little Angels Primary House	Provider Information	CLR No: L356305
Provider Address: 820 Pennsylvania Avenue, Bardstown, KY, 40004	Provider Type: LICENSED TYPE I	Capacity: 170
Owner(s): Little Angels Primary House II, LLC		Director(s): Wells, Elissa Louise

Inspection Type: Investigation	Inspection Information	Inspection No: 292250
Date Initiated: 11/13/2019 2:20 PM	Date Concluded: 11/14/2019 11:30 AM	
	No. of Children Present: 93	

Inspection Report	
Supervision	In Compliance
Staffing Requirements	In Compliance
Director Requirements	In Compliance
Premises	Not In Compliance

610 - Building Temperature **Not In Compliance**

922 KAR 2:120. Section 4. Premises Requirements.
(16) The temperature of the inside area of the premises shall be sixty-five (65) to eighty-two (82) degrees Fahrenheit.

Findings:

General: Based on interview and review of documentation, the child care center failed to maintain the premises in accordance with regulatory requirements. The two (2) toddlers classrooms, located at the rear of the building had a temperature reading of sixty-one (61) degrees on 11/14/2019, as indicated by the wall thermostats. Interview with staff revealed the two (2) classrooms had maintained a temperature reading of fifty-nine (59) degrees to sixty-one (61) for the dates of 11/13/2019 and 11/14/2019. Therefore the classrooms were not maintained at the minimum temperature of sixty-five (65) degrees.

Signature of _____ Title _____ Date _____
Provider/Representative