



Andy Beshear
GOVERNOR

CABINET FOR HEALTH AND FAMILY SERVICES
OFFICE OF INSPECTOR GENERAL

Eric Friedlander
SECRETARY

Melissa A. Moore, Director
Division of Regulated Child Care
Northern Branch
908 W. Broadway, 10-W
Louisville, KY 40203

Adam Mather
INSPECTOR GENERAL

Phone: (502) 595-5781 Fax: (502) 595-5773
<https://chfs.ky.gov/agencies/os/oig>

Inspection Report

Provider Name: Children - R - Us	Provider Information	CLR No: L356343
Provider Address: 815 Broadway Street, Brandenburg, KY, 40108	Provider Type: LICENSED TYPE I	Capacity: 70
Owner(s): Brown, Belinda Faye		Director(s): Brown, Belinda Faye

Inspection Type: Investigation	Inspection Information	Inspection No: 321979
Date Initiated: 07/01/2022 9:38 AM	Date Concluded: 07/01/2022 11:09 AM	
	No. of Children Present: 41	

Inspection Report	
Supervision	In Compliance
Staffing Requirements	In Compliance
Premises	Not In Compliance
655 - Building Temperature	Not In Compliance
922 KAR 2:120. Section 4. Premises Requirements.	
(16) The temperature of the indoor area of the premises shall be sixty-five (65) to eighty-two (82) degrees Fahrenheit.	
Findings:	
General: Review of documentation and interviews revealed the temperature inside the child care center reached eight-six (86) degrees Fahrenheit on June 24, 2022. Therefore, the temperature inside of the child care center was not maintained between sixty-five (65) degrees Fahrenheit and eighty-two degrees Fahrenheit.	

Signature of Provider/Representative

Title

Date