Printed Date: 12/02/2022 KID013A v2.0



Andy Beshear GOVERNOR

Provider Name: Jump Start Academy

CABINET FOR HEALTH AND FAMILY SERVICES OFFICE OF INSPECTOR GENERAL

Melissa A. Moore, Director **Division of Regulated Child Care**

Western Branch 901 B South Main Street Hopkinsville, KY 42240 Phone: (270) 889-6052 Fax: (270) 889-6089

https://chfs.ky.gov/agencies/os/oig

Eric Friedlander SECRETARY

Adam Mather INSPECTOR GENERAL

Inspection Report

Provider Information

Provider Type: LICENSED TYPE I

Capacity: 80

CLR No: 1 383774

Inspection No: 278843

Director(s): Romano, Toika Sue

Owner(s): Jump Start Academy LLC

Provider Address: 407 Brown Rd, Madisonville, KY, 42431

Inspection Type: Change of Location Date Initiated: 03/04/2019 1:30 PM **Inspection Information**

Date Concluded: 03/04/2019 2:10 PM

No. of Children Present:

Inspection Report

Background Checks

Staffing Requirements

General Administration

Director Requirements

Employee Records

Premises

Not In Compliance

Not In Compliance

In Compliance

In Compliance

In Compliance

In Compliance In Compliance

922 KAR 2:120. Section 10. Toilet, Diapering, and Toiletry Requirements.

(3) A sink shall be:

645 - Sink

- (a) Located in or immediately adjacent to toilet rooms;
- (b) Equipped with hot and cold running water that allows for hand washing;
- (c) Equipped with hot water at a minimum temperature of ninety (90) degrees Fahrenheit and a maximum of 120 degrees Fahrenheit;
- (d) Equipped with liquid soap;
- (e) Equipped with hand-drying blower or single use disposable hand drying material;
- (f) Equipped with an easily cleanable waste receptacle; and
- (g) Immediately adjacent to a changing area used for infants and toddlers.

Findings:

General: Based on observation and interview, the hot water temperature registered 130 degrees Fahrenheit at each handwashing sink in the infants', preschool and toddlers' rooms. The hot water temperature registered 130 degrees Fahrenheit at the handwashing sink in the children's restroom.

First Aid/Medication

Outdoor Play Area

Equipment

Food Service

Written Documentation

Posted Documentation

In Compliance

In Compliance

In Compliance

In Compliance

In Compliance

In Compliance





Date