Printed Date: 12/02/2022 KID013A v2.0



Andy Beshear GOVERNOR

CABINET FOR HEALTH AND FAMILY SERVICES OFFICE OF INSPECTOR GENERAL

Melissa A. Moore, Director **Division of Regulated Child Care**

Western Branch 901 B South Main Street Hopkinsville, KY 42240 Phone: (270) 889-6052 Fax: (270) 889-6089 https://chfs.ky.gov/agencies/os/oig

Eric Friedlander SECRETARY

Adam Mather INSPECTOR GENERAL

Inspection Report

Provider Information

Provider Type: LICENSED TYPE I

CLR No: 1358403

Inspection No: 292264

Capacity: 99

Director(s): Morales , Tammy Renee

Owner(s): Academy Of Learning-Harvard, LLC

Provider Address: 730 Harvard Drive, Owensboro, KY, 42301

Provider Name: Academy of Learning-Harvard

Inspection Type: Change of Location

Date Initiated: 12/12/2019 2:10 PM

Inspection Information

Date Concluded: 12/12/2019 3:30 PM

No. of Children Present:

Inspection Report

Supervision

General Administration

Programming

Premises

Not In Compliance

In Compliance

In Compliance

In Compliance

Not In Compliance

922 KAR 2:120. Section 10. Toilet, Diapering, and Toiletry Requirements.

(3) A sink shall be:

645 - Sink

- (a) Located in or immediately adjacent to toilet rooms;
- (b) Equipped with hot and cold running water that allows for hand washing;
- (c) Equipped with hot water at a minimum temperature of ninety (90) degrees Fahrenheit and a maximum of 120 degrees Fahrenheit;
- (d) Equipped with liquid soap;
- (e) Equipped with hand-drying blower or single use disposable hand drying material;
- (f) Equipped with an easily cleanable waste receptacle; and
- (g) Immediately adjacent to a changing area used for infants and toddlers.

Findings:

General: Based on testing the water temperature and interview, the hot water temperature registered eighty-two eight (82) degrees Fahrenheit at the sink in the Nursery. The hot water temperature registered one-hundred and thirty (130) degrees Fahrenheit at three (3) sinks in restrooms located in the hallway, to be utilized by children. In addition, the hot water temperature registered one-hundred and thirty (130) degrees Fahrenheit at the sink in the three-year-olds' classroom.

Outdoor Play Area

In Compliance

Equipment

In Compliance

Food Service

In Compliance

Posted Documentation

In Compliance

Signature of Provider/Representative



Date