



Department of Public Health and Human Services

FAMILY and GROUP DAY CARE FACILITIES (includes infant regulations) SURVEY TOOL

INSPECTION INFORMATION

Facility: Jill Sharon Smith / Twinkle Star Daycare

Type: Key Indicator Survey **Date:** 08/29/2017 **Time:** 03:10 PM

Director: Jill Sharon Smith

Contact: _____

Licensing Worker: Diana Lamers **Phone #:** (406) 751-5962

Time: 03:10 PM **# children:** 14 **# under 2:** 3 **# caregivers:** 2
Time: **# children:** **# under 2:** **# caregivers:**
Time: **# children:** **# under 2:** **# caregivers:**

STAFF RATIOS

Yes	1. License
Yes	2. Overlap

BUILDING/FIRE REQUIREMENTS

Yes	3. Inside Facility
Yes	4. Fire Safety
Yes	5. Equipment
No	<p>6. Exiting</p> <p>37.95.705(5)</p> <p>(5) All rooms used for napping by children must have at least two means of escape, at least one of which shall be a door or a stairway providing a means of unobstructed travel to the outside of the building at street or ground level to the public way. The second means of escape may be a window which meets the egress requirements of (2).</p> <p>The intent of this rule was not met:</p> <p>Based on observation and interview, CCL found that the window in the nap room had an AC unit installed which obstructed the exit.</p> <p>The Plan of Correction was accepted on September 14, 2017.</p>

OUTDOOR TOUR

Yes	7. Play Area
-----	--------------

HEALTH ISSUES

Yes	14. Health Prevention
-----	-----------------------

MEDICATION

Yes	16. Storage
-----	-------------

INFANTS/TODDLERS

Yes	17. Diapering
Yes	20. Sleeping

WRITTEN RECORDS

Yes	28. Parent Information
Yes	29. Facility Records
Yes	30. Child File Review
Yes	32. Caregiver File Review
Yes	33. First Aid Requirements