

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **United Childcare and Preschool #2** City: **Sioux Falls**

Provider Number: **000097002**

Inspector: **Dwight Johnson** Date of Inspection: **01/16/2020**

Time of Inspection: **2:24 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

<p>Corrections To Be Made:</p> <p>The measured water temperature in the boy's bathroom in the hallway is measured at 121.6 degrees F.</p> <p>*A Letter of Notification has been issued to give the program additional time to complete this project.</p> <p>**Water tested at 107 degrees.</p>	<p>Agency Action:</p> <p>Letter of Notification</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/31/2020</td> <td style="text-align: center;">04/23/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/31/2020	04/23/2020
Suggested Completion Date:	Actual Completion Date:				
08/31/2020	04/23/2020				

65. Is there a fenced outdoor play area? Does the fenced area appear to allow for 50 square feet per child during each scheduled recess time? 67:42:11:02

<p>Corrections To Be Made:</p> <p>The fence has been removed to install drainage tile to the playground. The fence will be reinstalled when the weather permits to do so.</p> <p>*A Letter of Notification has been issued to give the program additional time to complete this project.</p> <p>**Fence has been installed.</p>	<p>Agency Action:</p> <p>Letter of Notification</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/31/2020</td> <td style="text-align: center;">08/18/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/31/2020	08/18/2020
Suggested Completion Date:	Actual Completion Date:				
08/31/2020	08/18/2020				

C. FOOD SERVICE

76. Is food free from spoilage or contamination and safe for human consumption? 67:42:11:16

Corrections To Be Made:	Agency Action:	
Room 003 has a dorm style refrigerator that is measuring at a temperature of 45 degrees F.	Compliance Plan	
*Fridge tested at 40 degrees.	Suggested Completion Date:	Actual Completion Date:
	01/18/2020	02/12/2020
	Status: Corrected	

Judy Jacobs

Provider Signature

01/16/2020

Date

Dwight Johnson

Inspector Signature

01/16/2020

Date