

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Hand in Hand Community Daycare**

City: **Miller**

Provider Number: **000097047**

Inspector: **Clint Rux**

Date of Inspection: **08/25/2020**

Time of Inspection: **2:15 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>The storage room by the office had combustible items stored within 24" of the ceiling. Storage should not be stored within 24" of the ceiling.</p> <p>The combustible items in the storage room were moved to more than 24" from the ceiling.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">09/09/2020</td> <td style="text-align: center;">08/28/2020</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	09/09/2020	08/28/2020
Suggested Completion Date:	Actual Completion Date:				
09/09/2020	08/28/2020				

Jen Scnathorst

Provider Signature

08/25/2020

Date

Clint Rux

Inspector Signature

08/25/2020

Date