

Family Day Care Inspection Compliance Plan

Provider's Name: **Brittany Frias**

City: **Flandreau**

Provider Number: **010108163**

Inspector: **Rachel Holm**

Date of Inspection: **08/16/2018**

Time of Inspection: **2:25 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

C. Health & Safety Features of the Home - Indoor Environmental Observations

75. Is there an operating smoke detector with audible alarm located on each level of the home (regardless if level is used for care of children or not)? 67:42:03:11.02

<p>Corrections To Be Made:</p> <p>Main and lower level smoke detectors were not operational due to dead batteries.</p> <p>*New batteries were placed in the main and lower level smoke detectors.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/24/2018</td> <td style="text-align: center;">08/21/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	08/24/2018	08/21/2018
Suggested Completion Date:	Actual Completion Date:				
08/24/2018	08/21/2018				

Brittany Frias

Provider Signature

08/17/2018

Date

Rachel Holm

Inspector Signature

08/17/2018

Date