

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **First Baptist Childrens Center**      City: **Sioux Falls**

Provider Number: **010602017**

Inspector: **Charles Anderson**      Date of Inspection: **05/01/2018**

Time of Inspection: **11:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## **B. ENVIRONMENTAL HEALTH**

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?  
67:42:11:09

Corrections To Be Made:	Agency Action:	
<b>Hot water tested at 130 F in both the upper and lower bathrooms. The water temperature must be maintained at 120 degrees or lower.</b>	<b>Compliance Plan</b>	
	Suggested Completion Date:	Actual Completion Date:
	<b>05/15/2018</b>	<b>05/18/2018</b>
	Status: <b>Corrected</b>	

## **C. FOOD SERVICE**

76. Is food free from spoilage or contamination and safe for human consumption? 67:42:11:16

<p>Corrections To Be Made:</p> <p><b>A bottle of alcohol was found in the dry goods store room. Please ensure all hazardous materials are removed from areas where food is stored.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td>Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td><b>05/01/2018</b></td> <td><b>05/18/2018</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>05/01/2018</b>	<b>05/18/2018</b>
Suggested Completion Date:	Actual Completion Date:				
<b>05/01/2018</b>	<b>05/18/2018</b>				

80. Are potentially hazardous foods requiring cooking, cooked to heat all parts of the food to a temperature of at least 140 degrees F and held at that temperature until served or immediately refrigerated at 41 degrees F or below? 67:42:11:16

<p>Corrections To Be Made:</p> <p><b>All refrigerators / freezers need thermometers to ensure temperature is maintained at a safe level.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td>Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td><b>05/15/2018</b></td> <td><b>05/18/2018</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>05/15/2018</b>	<b>05/18/2018</b>
Suggested Completion Date:	Actual Completion Date:				
<b>05/15/2018</b>	<b>05/18/2018</b>				

**Sheena Christensen**  
 \_\_\_\_\_  
 Provider Signature

**05/01/2018**  
 \_\_\_\_\_  
 Date

**Charles Anderson**  
 \_\_\_\_\_  
 Inspector Signature

**05/01/2018**  
 \_\_\_\_\_  
 Date