

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Little Blessings Daycare**

City: **Watertown**

Provider Number: **010602510**

Inspector: **Kelly Gnat**

Date of Inspection: **01/22/2019**

Time of Inspection: **11:01 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

<p>Corrections To Be Made:</p> <p>Hot water temps in the bathrooms where children wash their hands exceeded 120 degrees.</p> <p>**Water temps were turned down in both bathrooms and were set between 100-110 degrees.**</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">02/05/2019</td> <td style="text-align: center;">02/25/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	02/05/2019	02/25/2019
Suggested Completion Date:	Actual Completion Date:				
02/05/2019	02/25/2019				

Kjirsten Fisk

Provider Signature

01/22/2019

Date

Kelly Gnat

Inspector Signature

01/22/2019

Date