Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: Wagner Early Childhood Center City: Wagner Provider Number: 010603037

Inspector: Kenneth Date of Inspection: 06/17/2019 Time of Inspection: 9:30 AM

Anderson

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

Corrections To Be Made: Agency Action:

There are combustible materials stored less than 2 feet from the ceiling.

Compliance Plan

*Combustible items were moved to location more than 2 feet from ceiling.

Suggested Completion Date:

Actual Completion Date:

06/22/2019

06/18/2019

Status: Corrected

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

Corrections To Be Made: Agency Action:

An annual inspection is needed for the fire extinguishers. Compliance Plan

*Extinguishers were inspected on 07/15/19 to verify that they are operable.

Suggested Completion Date:

Actual Completion Date:

07/15/2019

06/30/2019

Status: Corrected

Pamela Beeson	06/17/2019	Kenneth Anderson	06/17/2019
Provider Signature	Date	Inspector Signature	Date