

Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Kid's Inc-Hawthorne**

City: **Sioux Falls**

Provider Number: **010605116**

Inspector: **Dwight Johnson**

Date of Inspection: **03/03/2020**

Time of Inspection: **4:00 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

17. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>Documentation for the annual heating and cooling system inspection was not available at the time of the inspection.</p> <p>The heating and cooling system must be maintained and inspected annually.</p> <p>Due to the COVID 19 Pandemic, the program is currently closed.</p> <p>Correction: Documentation for the annual heating and cooling system was submitted to Child Care Services.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">04/03/2020</td> <td style="text-align: center;">06/08/2020</td> </tr> <tr> <td colspan="2">Status: Corrected</td> </tr> </table>	Suggested Completion Date:	Actual Completion Date:	04/03/2020	06/08/2020	Status: Corrected	
Suggested Completion Date:	Actual Completion Date:						
04/03/2020	06/08/2020						
Status: Corrected							

Kelly Gaalswyk

03/03/2020

Dwight Johnson

03/03/2020

Provider Signature

Date

Inspector Signature

Date