

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Angel Care Day Care**

City: **Sturgis**

Provider Number: **010606036**

Inspector: **Terra Robbins**

Date of Inspection: **10/04/2018**

Time of Inspection: **10:21 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

12. Are portable fire extinguishers charged and operable? 61:15:06:09 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

<p>Corrections To Be Made:</p> <p>Fire extinguisher is in the green but requires an annual inspection.</p> <p>CORRECTION: Provider purchased a new fire extinguisher.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">11/04/2018</td> <td style="text-align: center;">10/15/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	11/04/2018	10/15/2018
Suggested Completion Date:	Actual Completion Date:				
11/04/2018	10/15/2018				

Donna Fedderson

10/04/2018

Provider Signature

Date

Terra Robbins

10/04/2018

Inspector Signature

Date