

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Allen Learning Center**

City: **Allen**

Provider Number: **010606888**

Inspector: **Jennifer Preuninger**

Date of Inspection: **03/08/2018**

Time of Inspection: **9:38 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

43. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

<p>Corrections To Be Made:</p> <p>The last heating and cooling inspection report was in 2016. Heating and cooling systems must be inspected on a yearly basis.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/22/2018</td> <td style="text-align: center;">03/27/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	03/22/2018	03/27/2018
Suggested Completion Date:	Actual Completion Date:				
03/22/2018	03/27/2018				

Vicki Dubray

Provider Signature

06/15/2018

Date

Jennifer Preuninger

Inspector Signature

06/15/2018

Date