## Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name:	Ipswich Tiger Post C	EC City:	lpswich	Provider Number:	011100998
Inspector:	Clint Rux	Date of Inspection:	03/04/2020	Time of Inspection:	4:25 PM

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

1. Are written emergency evacuation plans posted? 67:42:10:18

Corrections To Be Made:	Agency Action:	
The emergency evacuation plans were not posted. Compliance Plan		
The Provider has posted the emergency evacuation plans at the program.	Suggested Completion Date:	Actual Completion Date:
	03/24/2020	03/11/2020
	Status: Corrected	

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

	Status: Correcte	ed
	03/24/2020	03/21/2020
The fire extinguishers have been moved to the new facility.	Completion Date:	Completion Date:
Fire extinguishers have not been brought over from the old building. These need to be in place before operation.	Compliance Plan Suggested	Actual
Corrections To Be Made:	Agency Action:	

## **B. ENVIRONMENTAL HEALTH**

65. Is there a fenced outdoor play area? Does the fenced area appear to allow for 50 square feet per child during each scheduled recess time? 67:42:11:02

Corrections To Be Made:	Agency Action:		
The outdoor area for the playground is not fenced.	Letter of Notification	Letter of Notification	
The Provider will ensure the children are always supervised while outdoors. The Provider agreed to install a fence around the outdoor play area by June 15, 2020.	Suggested Completion Date:	Actual Completion Date:	
	04/04/2020	05/29/2020	
	Status: Corrected		

## **Miscellaneous Rule Violations**

61:15:05:05 - Exit requirements.

Corrections To Be Made:	Agency Action:		
The South exits from the building do not open to a landing, or concrete pad. These exits must have a landing that is at the same level as the floor. The Provider will ensure there is no safety concern with exiting in the event of a fire until the platform/steps are installed. The Provider agreed to install landings outside the exit that meet the requirements by June 15, 2020.	Letter of Notificati Suggested Completion Date: 04/04/2020	Completion Completion Date: Date:	
	Status: Corrected	I	

Madeline Miller Provider Signature 03/04/2020 Date Clint Rux Inspector Signature 03/04/2020

Date

011100998 - 03/04/2020