

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **SWST Head Start East**

City: **Agency Village**

Provider Number: **011102376**

Inspector: **Eric Janke**

Date of Inspection: **09/11/2018**

Time of Inspection: **9:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

44. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?
67:42:11:09

Corrections To Be Made:

Water temp in room sink is 127.2 degrees. The Provider can turn down the hot water temperature to meet compliance. Provider turned down the hot water temperature to 103 degrees.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

10/11/2018

Actual
Completion
Date:

10/03/2018

Status: **Corrected**

Lynn Halbert

Provider Signature

09/11/2018

Date

Eric Janke

Inspector Signature

09/11/2018

Date