

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Journey Kid's Daycare Center**      City: **Aberdeen**

Provider Number: **011102398**

Inspector: **Clint Rux**      Date of Inspection: **08/12/2020**

Time of Inspection: **3:45 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p><b>The outlet by the girl's bathroom in the south building was not self-closing, or tamper resistant.</b></p> <p><b>The outlet cover was replaced with a self-closing outlet cover.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td style="padding-right: 20px;">Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td style="padding-right: 20px;"><b>09/12/2020</b></td> <td><b>09/15/2020</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>09/12/2020</b>	<b>09/15/2020</b>
Suggested Completion Date:	Actual Completion Date:				
<b>09/12/2020</b>	<b>09/15/2020</b>				

18. Are portable fire extinguishers charged and operable? 61:15:05:10 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

<p>Corrections To Be Made:</p> <p><b>The fire extinguishers in the south building was last inspected in November of 2018. This needs to be checked annually.</b></p> <p><b>The fire extinguishers have been inspected by a service agent.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table border="0"> <tr> <td style="padding-right: 20px;">Suggested Completion Date:</td> <td>Actual Completion Date:</td> </tr> <tr> <td style="padding-right: 20px;"><b>09/12/2020</b></td> <td><b>09/15/2020</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>09/12/2020</b>	<b>09/15/2020</b>
Suggested Completion Date:	Actual Completion Date:				
<b>09/12/2020</b>	<b>09/15/2020</b>				

**Devin Hebeisen**

Provider Signature

**08/12/2020**

Date

**Clint Rux**

Inspector Signature

**08/12/2020**

Date