

# Facility Safety Inspection

## Fire & Life Safety / Environmental Health

### Licensed Day Care Programs

### Compliance Plan

Provider's Name: **Westside Preschool Program**

City: **Sisseton**

Provider Number: **011102433**

Inspector: **Eric Anderson**

Date of Inspection: **09/09/2020**

Time of Inspection: **1:32 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

#### A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

Corrections To Be Made:

**One outlet is not protected or covered.**

**The outlet cover was replaced with a self-closing outlet cover.**

Agency Action:

#### Compliance Plan

Suggested  
Completion  
Date:

**09/23/2020**

Actual  
Completion  
Date:

**09/14/2020**

Status: **Corrected**

**Carol Jensen**

Provider Signature

**09/09/2020**

Date

**Eric Anderson**

Inspector Signature

**09/09/2020**

Date