

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Schoolhouse Daycare**

City: **Veblen**

Provider Number: **011102438**

Inspector: **Eric Anderson**

Date of Inspection: **09/09/2020**

Time of Inspection: **11:43 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

Corrections To Be Made:

**Outlets in library must be covered while children under 5 are present in the room.**

**The program added tamper resistant outlets in the library.**

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

**09/16/2020**

Actual  
Completion  
Date:

**11/06/2020**

Status: **Corrected**

**Jessica Martinez**

Provider Signature

**09/09/2020**

Date

**Eric Anderson**

Inspector Signature

**09/09/2020**

Date