

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Licensed Day Care Programs

Compliance Plan

Provider's Name: **Bright Beginnings Childcare & Learning Center** City: **Aberdeen**

Provider Number: **011102449**

Inspector: **Clint Rux**

Date of Inspection: **07/27/2020**

Time of Inspection: **2:30 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

11. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

Corrections To Be Made:

The exit signs over the East door is not illuminated. The exit light over the North door by the kitchen is not illuminated. These need to be maintained in luminous condition.

The light bulbs in the exit signs over the east door and north door near the kitchen were replaced and they illuminated.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

08/10/2020

Actual
Completion
Date:

09/01/2020

Status: **Corrected**

B. ENVIRONMENTAL HEALTH

50. Is the heating and cooling system maintained and inspected annually? 67:42:11:12

Corrections To Be Made:

The records were not available due to the director was not in the facility at the time of the inspection.

The heating and cooling system has been inspected by a service agent.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/10/2020

Actual
Completion
Date:

09/24/2020

Status: **Corrected**

Shelley Barr

Provider Signature

07/27/2020

Date

Clint Rux

Inspector Signature

07/27/2020

Date