

Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Faulkton Area OST Program**

City: **Faulkton**

Provider Number: **011102455**

Inspector: **Eric Janke**

Date of Inspection: **10/02/2018**

Time of Inspection: **3:07 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

3. Is the fire alarm system operable? 61:15:05:08

<p>Corrections To Be Made:</p> <p>Fire alarm reads "trouble smoke(photo) west admin corridor dirty2 04:40P 092618 1D038. The fire alarm system needs to be operable. The fire alarm head was replaced and tested and the fire alarm system is operable.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">10/09/2018</td> <td style="text-align: center;">10/08/2018</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	10/09/2018	10/08/2018
Suggested Completion Date:	Actual Completion Date:				
10/09/2018	10/08/2018				

Desi Holsworth

10/02/2018

Provider Signature

Date

Eric Janke

10/02/2018

Inspector Signature

Date