

Facility Safety Inspection

Fire & Life Safety / Environmental Health

Before & After School Center - School Location

Compliance Plan

Provider's Name: **Summit 21st CEC**

City: **Summit**

Provider Number: **011102468**

Inspector: **Eric Janke**

Date of Inspection: **09/05/2018**

Time of Inspection: **3:47 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

B. ENVIRONMENTAL HEALTH

22. At sinks used by children, is the hot water maintained at a temperature that does not exceed 120 degrees F? 67:42:11:06

Corrections To Be Made:

Children's bathroom water temperature is 156.5. Turn down hot water heater. The program turned down the hot water heater to meet the regulation of 120 degrees or lower.

Agency Action:

Compliance Plan

Suggested
Completion
Date:

09/10/2018

Actual
Completion
Date:

10/09/2018

Status: **Corrected**

Becky Hubsch

Provider Signature

09/05/2018

Date

Eric Janke

Inspector Signature

09/05/2018

Date