

# Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Little Sprouts Preschool**

City: **Aberdeen**

Provider Number: **011102473**

Inspector: **Clint Rux**

Date of Inspection: **08/13/2018**

Time of Inspection: **10:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## A. FIRE AND LIFE SAFETY

12. Are portable fire extinguishers charged and operable? 61:15:06:09 NOTE: Minimum 2A rated on each level. No more than 75 feet travel distance to an extinguisher. One near food preparation.

<p>Corrections To Be Made:</p> <p><b>Fire extinguishers need to be inspected annually by a service agent. The fire extinguishers were inspected by a service agent.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>08/30/2018</b></td> <td style="text-align: center;"><b>09/18/2018</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>08/30/2018</b>	<b>09/18/2018</b>
Suggested Completion Date:	Actual Completion Date:				
<b>08/30/2018</b>	<b>09/18/2018</b>				

## B. ENVIRONMENTAL HEALTH

37. Is the water temperature at children's hand washing sinks maintained at 120 degrees or lower?  
67:42:11:09

Corrections To Be Made:

The water temp in the boy's restroom was 133.2 and 127.2 in the girl's restroom. These need to be adjusted to be 120 degrees, or less. The hot water heater was turned down to 118 degrees.

Agency Action:

**Compliance Plan**

Suggested  
Completion  
Date:

Actual  
Completion  
Date:

**08/30/2018**

**09/18/2018**

Status: **Corrected**

**Regina Holcomb**

Provider Signature

**08/13/2018**

Date

**Clint Rux**

Inspector Signature

**08/13/2018**

Date