

Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Great After School Place -
Hilcrest Elementary Program**

City: **Brookings**

Provider Number: **011512104**

Inspector: **Charles Schmidt**

Date of Inspection: **02/27/2018**

Time of Inspection: **4:52 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

4. Are exit signs provided over each exit, and where necessary to identify a change in the direction of egress travel? 61:15:05:05 NOTE: Exit signs must be interior or exterior illuminated or self-luminous.

<p>Corrections To Be Made:</p> <p>Repair exit sign over north west exit from main room.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">03/02/2018</td> <td style="text-align: center;">03/19/2018</td> </tr> <tr> <td colspan="2" style="text-align: center;">Status: Corrected</td> </tr> </table>	Suggested Completion Date:	Actual Completion Date:	03/02/2018	03/19/2018	Status: Corrected	
Suggested Completion Date:	Actual Completion Date:						
03/02/2018	03/19/2018						
Status: Corrected							

Kory Kinter

Provider Signature

02/27/2018

Date

Charles Schmidt

Inspector Signature

02/27/2018

Date