

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Sunnyside Daycare**

City: **Pierre**

Provider Number: **011517588**

Inspector: **Brian DeShazer**

Date of Inspection: **12/09/2019**

Time of Inspection: **9:00 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p>School-age room East wall outlet is not self-closing.</p> <p>The outlet in the school-age room was replaced with a self-closing outlet.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">12/19/2019</td> <td style="text-align: center;">12/19/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	12/19/2019	12/19/2019
Suggested Completion Date:	Actual Completion Date:				
12/19/2019	12/19/2019				

20. NEW PROGRAMS: Are all requirements identified in the floor plan review letter issued by the Fire Marshall's Office completed? Does facility layout match the approved floor plan? 67:42:10:18

<p>Corrections To Be Made:</p> <p>School-age room East wall outlet needs changed out to self- closing, outlet. The exit door in SE corner basement exit is sticking.</p> <p>The outlet in the school-age room was replaced with a self-closing outlet and the exit door was repaired.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">12/19/2019</td> <td style="text-align: center;">12/19/2019</td> </tr> </table> <p>Status: Corrected</p>	Suggested Completion Date:	Actual Completion Date:	12/19/2019	12/19/2019
Suggested Completion Date:	Actual Completion Date:				
12/19/2019	12/19/2019				

Katie BigEagle

Provider Signature

12/09/2019

Date

Brian DeShazer

Inspector Signature

12/09/2019

Date