

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Shining Star Academy**

City: **Wagner**

Provider Number: **014512043**

Inspector: **Kenneth
Anderson**

Date of Inspection: **07/25/2018**

Time of Inspection: **10:34 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

10. If providing care for children under 5 years of age, are there self-closing, or tamper resistant childproof electrical covers on all outlets? 67:42:11:10

<p>Corrections To Be Made:</p> <p>Outlets by high chairs need self-closing or tamper resistant covers.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">07/26/2018</td> <td style="text-align: center;">08/01/2018</td> </tr> <tr> <td colspan="2" style="text-align: center;">Status: Corrected</td> </tr> </table>	Suggested Completion Date:	Actual Completion Date:	07/26/2018	08/01/2018	Status: Corrected	
Suggested Completion Date:	Actual Completion Date:						
07/26/2018	08/01/2018						
Status: Corrected							

Dorothy Spease

Provider Signature

08/02/2018

Date

Kenneth Anderson

Inspector Signature

08/02/2018

Date