

Facility Safety Inspection Fire & Life Safety / Environmental Health Licensed Day Care Programs Compliance Plan

Provider's Name: **Shining Star Academy**

City: **Wagner**

Provider Number: **014512043**

Inspector: **Kenneth Anderson**

Date of Inspection: **07/30/2019**

Time of Inspection: **8:22 AM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

A. FIRE AND LIFE SAFETY

14. In storage rooms, are combustible materials maintained at least 2 feet below the ceiling or 18 Inches below sprinkler head deflectors? 67:42:10:18

<p>Corrections To Be Made:</p> <p>In the office area there are combustible items stored less than 2 feet from the ceiling.</p> <p>*Items were moved/issue corrected during the inspection.</p>	<p>Agency Action:</p> <p>Compliance Plan</p> <table style="width: 100%;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;">08/15/2019</td> <td style="text-align: center;">07/30/2019</td> </tr> </table> <p>Status: Corrected Immediately</p>	Suggested Completion Date:	Actual Completion Date:	08/15/2019	07/30/2019
Suggested Completion Date:	Actual Completion Date:				
08/15/2019	07/30/2019				

Dorothy Spease

Provider Signature

07/30/2019

Date

Kenneth Anderson

Inspector Signature

07/30/2019

Date