

# Facility Safety Inspection Fire & Life Safety / Environmental Health Before & After School Center - School Location Compliance Plan

Provider's Name: **Oahe YMCA**

City: **Pierre**

Provider Number: **015500848**

Inspector: **Kelly Gnat**

Date of Inspection: **07/13/2020**

Time of Inspection: **2:45 PM**

The items listed below are those that the provider was not in compliance with at the time of the inspection.

## B. ENVIRONMENTAL HEALTH

22. At sinks used by children, is the hot water maintained at a temperature that does not exceed 120 degrees F? 67:42:11:06

<p>Corrections To Be Made:</p> <p><b>The water temp upstairs was 148 degrees. Turn the water temp down to 120 degrees or install a faucet water mixer as a means to ensure the water temp does not exceed 120 degrees.</b></p> <p><b>Correction: The water temp was turned down to 120 degrees.</b></p>	<p>Agency Action:</p> <p><b>Compliance Plan</b></p> <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;">Suggested Completion Date:</td> <td style="width: 50%;">Actual Completion Date:</td> </tr> <tr> <td style="text-align: center;"><b>07/20/2020</b></td> <td style="text-align: center;"><b>07/28/2020</b></td> </tr> </table> <p>Status: <b>Corrected</b></p>	Suggested Completion Date:	Actual Completion Date:	<b>07/20/2020</b>	<b>07/28/2020</b>
Suggested Completion Date:	Actual Completion Date:				
<b>07/20/2020</b>	<b>07/28/2020</b>				

**Lisa Maunu**

**07/13/2020**

**Kelly Gnat**

**07/13/2020**

Provider Signature

Date

Inspector Signature

Date